



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

January 16, 2019

System No. 3500916

Ross Hillyard
Kingdom Hall (Fallon Rd)
921 Joe Borovich Dr.
Hollister, CA 95023

CITATION NO. 02_05_19C_002 TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION FOR DECEMBER 2018

Enclosed is Citation No. 02_05_19C_002 (hereinafter "Citation"), issued to the Kingdom Hall (Fallon Rd) (hereinafter "Kingdom Hall"), public water system. Please note that there are legally enforceable deadlines associated with this Citation.

The Kingdom Hall will be billed at the State Water Resources Control Board's (hereinafter "State Water Board"), hourly rate for the time spent on issuing this Citation. California Health and Safety Code, (hereinafter "CHSC"), Section 116577, provides that a public water system must reimburse the State Water Board for actual costs incurred by the State Water Board for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation. At this time, the State Water Board has spent approximately one hour on enforcement activities associated with this violation.

The Kingdom Hall will receive a bill sent from the State Water Board in August of the next fiscal year. This bill will contain fees for any enforcement time spent on the Kingdom Hall for the current fiscal year.

Any person who is aggrieved by a citation, order or decision issued under authority delegated to an officer or employee of the state board under Article 8 (commencing with CHSC, Section 116625) or Article 9 (commencing with CHSC, Section 116650), of the Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4), may file a petition with the State Water Board for reconsideration of the citation, order or decision. Appendix 1 to the enclosed Citation contains the relevant statutory provisions for filing a petition for reconsideration (CHSC, Section 116701).

FELICIA MARCUS, CHAIR | EILEEN SOBECK, EXECUTIVE DIRECTOR

1 Lower Ragsdale, Bldg. 1, Suite 120, Monterey, CA 93940 | www.waterboards.ca.gov


Petitions must be received by the State Water Board within 30 days of the issuance of the citation, order or decision by the officer or employee of the state board. The date of issuance is the date when the Division of Drinking Water mails a copy of the citation, order or decision. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day by 5:00 p.m.

Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact Jonathan Weininger of my staff at (831) 655-6932 or me at (831) 655-6934.

Sincerely,



Jan R. Sweigert, P.E.
District Engineer, Monterey District Office
Northern California Field Operations Branch
Division of Drinking Water

Enclosures

Certified Mail No. 7008 1830 0004 5435 1261

Email cc: San Benito County Environmental Health Department
Bob Overcash bobgovercash@gmail.com
Thomas A. Estrada, tae733@garlic.com

STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Name of Public Water System: Kingdom Hall

Water System No: 3500916

Attention: Ross Hillyard
921 Joe Borovich Dr.
Hollister, CA 95023

Issued: January 16, 2019

**CITATION FOR NONCOMPLIANCE WITH
CALIFORNIA HEALTH AND SAFETY CODE, SECTION 116555(a)(1) AND
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1**

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL VIOLATION
DECEMBER 2018**

The California Health and Safety Code (hereinafter "CHSC"), Section 116650 authorizes the State Water Resources Control Board (hereinafter "State Water Board"), to issue a citation to a public water system when the State Water Board determines that the public water system has violated or is violating the California Safe Drinking Water Act (hereinafter "California SDWA"), (CHSC, Division 104, Part 12, Chapter 4, commencing with Section

1 116270), or any regulation, standard, permit, or order issued or adopted
2 thereunder.

3
4 The State Water Board, acting by and through its Division of Drinking Water
5 (hereinafter "Division") and the Deputy Director for the Division, hereby issues
6 Citation No. 02_05_19C_002 (hereinafter "Citation"), pursuant to Section
7 116650 of the CHSC to the Kingdom Hall (hereinafter "Kingdom Hall"), for
8 violation of CHSC, Section 116555(a)(1) and California Code of Regulations
9 (hereinafter "CCR"), Title 22, Section 64426.1.

10
11 Applicable statutes and regulations are available on the State Water Board
12 website at:

13 [https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Lawboo](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Lawbook.html)
14 [k.html](https://www.waterboards.ca.gov/drinking_water/certlic/drinkingwater/Lawbook.html)

15 16 **STATEMENT OF FACTS**

17 The Kingdom Hall is classified as a transient noncommunity public water
18 system with a population of 250-300, serving one connection. The Kingdom
19 Hall operates under Domestic Water Supply Permit No. 02-05-18P-3500916
20 issued by the State Water Board on July 6, 2018.

21
22 CHSC, Section 116555(a)(1) requires all public water systems to comply with
23 primary drinking water standards as defined in CHSC, Section 116275(c).
24 Primary drinking water standards include maximum levels of contaminants
25 and the monitoring and reporting requirements as specified in regulations
26 adopted by the State Water Board that pertain to maximum contaminant
27 levels.

CCR, Title 22, Section 64426.1, Total Coliform Maximum Contaminant Level (hereinafter "MCL"), states that a public water system is in violation of the total coliform MCL if it collects fewer than 40 bacteriological samples per month and if more than one sample collected during any month is total coliform-positive.

The State Water Board received laboratory results for nine bacteriological samples collected during December 2018 from the Kingdom Hall. All samples were analyzed for the presence of total coliform bacteria. Four of the nine samples analyzed were positive for total coliform bacteria. None of the total coliform positive samples showed the presence of *Escherichia coli* (*E. coli*) bacteria.

On December 20, 2018, Kingdom Hall submitted a completed Level 1 Assessment investigation report to the State Water Board pertaining to the total coliform MCL exceedance that occurred during December 2018. The State Water Board accepted the Level 1 Assessment.

Kingdom Hall sent the Division a copy of the public notification distributed on December 27, 2018 and proof of notification, dated January 5, 2019. The notification was completed in accordance with CCR, Title 22, Section 64426.1, 64463.4(b) and (c) and 64465.

DETERMINATION

The Kingdom Hall took fewer than 40 bacteriological samples during December 2018. The results of four routine samples were total coliform positive. Therefore, the State Water Board has determined that the Kingdom Hall has failed to comply with drinking water standards pursuant to CHSC,

Section 116555(a)(1) and CCR, Title 22, Section 64426.1 during December 2018.

DIRECTIVES

The Kingdom Hall is hereby directed to take the following actions:

1. Pursuant to CCR, Title 22, Section 64424(d), collect and have analyzed for total coliform bacteria, five (5) routine bacteriological samples on or before **January 31, 2019**.
2. The Kingdom Hall shall include this violation in the 2018 Consumer Confidence Report in accordance with CCR, Title 22, Section 64481(d)(3).

All submittals required by this Citation shall be electronically submitted to the State Water Board at the following address. The subject line for all electronic submittals corresponding to this Citation shall include the following information: Water System name and number, citation number and title of the document being submitted.

Jan R. Sweigert, P.E.

Dwpdist05@waterboards.ca.gov

The State Water Board reserves the right to make modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

1 Nothing in this Citation relieves the Kingdom Hall of its obligation to meet the
2 requirements of the California SDWA (CHSC, Division 104, Part 12, Chapter
3 4, commencing with Section 116270), or any regulation, standard, permit or
4 order issued or adopted thereunder.

6 **PARTIES BOUND**

7 This Citation shall apply to and be binding upon the Kingdom Hall, its owners,
8 shareholders, officers, directors, agents, employees, contractors, successors,
9 and assignees.

11 **SEVERABILITY**

12 The directives of this Citation are severable, and the Kingdom Hall shall
13 comply with each and every provision thereof notwithstanding the
14 effectiveness of any provision.

16 **FURTHER ENFORCEMENT ACTION**

17 The California SDWA authorizes the State Water Board to: issue a citation or
18 order with assessment of administrative penalties to a public water system for
19 violation or continued violation of the requirements of the California SDWA or
20 any regulation, permit, standard, citation, or order issued or adopted
21 thereunder including, but not limited to, failure to correct a violation identified
22 in a citation or compliance order. The California SDWA also authorizes the
23 State Water Board to take action to suspend or revoke a permit that has been
24 issued to a public water system if the public water system has violated
25 applicable law or regulations or has failed to comply with an order of the State
26 Water Board, and to petition the superior court to take various enforcement
27 measures against a public water system that has failed to comply with an

1 order of the State Water Board. The State Water Board does not waive any
2 further enforcement action by issuance of this Citation.

3
4 Jan Sweigert
5

6 Jan R. Sweigert, P.E.
7 District Engineer, Monterey District Office
8 Northern California Field Operations Branch
9 Division of Drinking Water

1/16/2019

Date



10
11 Certified Mail No. 7008 1830 0004 5435 1261